

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E533529  
**Report Reference** E533529-20230322  
**Issue Date** 2023-MARCH-22

**Issued to:** ETAC Service & Supply Inc.  
38 Terracon PI  
Winnipeg, MB, R2J 4G7  
CA

**This certificate confirms that representative samples of** TRANSFORMERS, DISTRIBUTION, LIQUID-FILLED TYPE, OVER 600 VOLTS

See Addendum Page for Model(s)

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** IEEE C57.12.00, 1st Ed., Issue Date: 2015-12-05, IEEE C57.12.28, 1st Ed., Issue Date: 2014-05-16  
CSA C2.1-06, 1st Ed., Issue Date: 2006-03-01, Revision Date: 2007-02-01, CSA C227.3-06, 4th Ed., Issue Date: 2006-03-01, Revision Date: 2007-03-01, CSA C227.4-06, 2nd Ed., Issue Date: 2006-03-01, Revision Date: 2007-08-01

**Additional Information:** See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Conformity Assessment Director

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>




# CERTIFICATE OF COMPLIANCE

**Certificate Number** E533529  
**Report Reference** E533529-20230322  
**Issue Date** 2023-MARCH-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model(s), ETACss-DI- XXXX/YY(YY/2)/zzzzz [a].

[a]- Where XXXX could be 0000~3000, represents power 0~3000KVA, YY could be 17~28, represents Hv voltage 17KV~28KV, (YY/2) is optional, represents Hv voltage 8.5KV~14KV when Hv windings in parallel, zzzzz could be 0.000 ~1.200, represents LV voltage 0V~1.2kV. |



Bruce Mahrenholz, Conformity Assessment Director

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/about/locations/>

